

Metropolitan Washington Airports Authority
PROCUREMENT AND CONTRACTS DEPT.
AMENDMENT OF SOLICITATION

Metropolitan Washington Airports Authority Procurement and Contracts Dept., MA-440 1 Aviation Circle, Suite 154 Washington, DC 20001-6000 Telephone: (703) 417-8660	1A. AMENDMENT OF SOLICITATION NO.	1B. DATED
	1-08-C130	April 10, 2008
	2A. AMENDMENT NO.	2B. EFFECTIVE DATE
	One (0001)	May 9, 2008

The solicitation identified in Block 1A is amended as set forth in Block 3. Hour and date specified for receipt of offers is extended, is not extended. Offerors must acknowledge receipt of this amendment prior to the hour and dated specified in the solicitation or as amended, by one of the following methods: (a) by completing Block 4 and returning copy of the amendment; (b) by acknowledging receipt of this amendment on the Solicitation Offer and Award Sheet, Block 13. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.

3. DESCRIPTION OF AMENDMENT

The Metropolitan Washington Airports Authority solicitation entitled "Route 28 Concrete Wall Extension at Dulles International Airport" is amended as follows:

- 1. The Deadline for offer submission remains unchanged.**
2. Section X, Attachments 01 and 02 – Incorporate the attached Addendum No. 1, dated May 8, 2008, one (1) page.
3. All other terms and conditions of the solicitation remain unchanged.

Except as provided herein, all terms and conditions of the document referenced in Block 1A, as heretofore changed, remain unchanged and in full force and effect.

4A. NAME AND TITLE OF OFFEROR	4B. SIGNATURE	4C. DATE

**ADDENDUM NO. 1
SOLICITATION 1-08-C130,
ROUTE 28 CONCRETE WALL EXTENSION
MAY 8, 2008**

Specifications

Section 011000 SUMMARY

REVISE paragraph 1.3.B to read as follows:

- “A. Architect/Engineer Identification: The Contract Documents, dated February 13, 2008, were prepared for Project by Burns Engineering, 6700 Old McLean Village Drive, Suite 201, McLean, VA 22101.”

Section 16850 VIDEO SURVEILLANCE SYSTEM

REVISE paragraph 3.10.C to read as follows:

- “C. Spare Parts: Contractor to provide spare parts encompassing 5% of the total material scope, spare parts recommended by the manufacturer, plus 100% of all equipment listed below. Cost to supply these parts shall be included in contract. List to be submitted to Owner for final review before parts are ordered.
1. Provide one spare Indoor/Outdoor Color Pan/Tilt/Zoom Cameras as described in section 2.2 of this specification.
 2. Provide one spare camera housing with all accessories as described in section 2.2 of this specification.
 3. Provide one spare Fiber Optic/Coaxial Converter as described in section 2.2 of this specification.
 4. Provide one spare Plug-And-Play UPS as described on drawings.”

Drawings

GN01.01 GENERAL NOTES AND LEGEND

Delete Visual Barrier Wall Note 14 in its entirety.