

**RONALD REAGAN WASHINGTON NATIONAL AIRPORT
METROPOLITAN WASHINGTON AIRPORTS AUTHORITY
SOLICITATION NO. 1-09-C118**

**MAINTAIN, INSPECT AND REPAIR THE
UNINTERRUPTIBLE POWER SUPPLY (UPS) SYSTEMS**

**July 6, 2009
QUESTION AND ANSWER RESPONSE #2**

1. The four hour response by certified technician. Does this technician require the proprietary MGE software?

Response: Yes

2. Does the Authority currently have spare parts kits for all UPS models?

Response: No. There is a parts kit for the MGE units only.

3. Equipment list: two items have a manufacturer other than MGE. It is 'Controlled Power'. Can you please identify these items further?

Response: The model and serial numbers are listed on Attachment A.